

DATE:	July 30, 2020
TO:	Gregg Dohrn
FROM:	Blueline
RE:	Water and Sewer Service - Phase 1A and Full Buildout

Per Appendix D and Appendix E of the Development Agreement, the City is to provide sewer and water service for the first 140 ERUs constructed within City Heights.

The proposed water system for the City Heights development was modeled by HLA Engineering and Land Surveying, Inc. (HLA) using the City's hydraulic model. The model includes full buildout demand. Refer to letter prepared by HLA documenting design assumptions, exhibit prepared by Blueline showing the conceptual location of watermain for the City Heights development and the Sewer & Water Plan prepared by Blueline showing the proposed water system for Phase 1A.

The lot counts provided in the exhibit prepared by Blueline showing the conceptual location of watermain for the City Heights development can be used to determine sewer loading.



June 17, 2020

Blueline 25 Central Way, Suite 400 Kirkland, WA 98033

Attn: Brett Pudists, PE

Re: City of Cle Elum City Heights Water Main Sizing HLA Project No. 20063E

Dear Brett:

On May 22, 2020 Blueline sent HLA a conceptual plan for the City Heights development for full buildout, and requested assistance determining what water main size is required and serviceability for higher elevation services.

HLA input the conceptual layout in the City's water system model and considered the following assumptions:

- Maximum Day Demand (MDD) as determined by Cle Elum's 2014 Water System Plan including Fire Flow is the active scenario.
- All parcels are assumed to be developed as single-family residential services.
- Minimum static pressure provided is 40 psi, and minimum fire flow is 1,000 gpm at 20 psi residual pressure.
- Fire suppression and equalizing storage components are depleted for the active scenario.
- Elevations assigned to nodes are based on contours on exhibit provided by Blueline.
- Only water main represented by a solid line were input in the model, with nodes at each junction with service laterals.
- PRV diameters are assumed 6-inch, and initially set to maintain a discharge at 30 psi, but were then changed to 40 psi after initial model results showed much lower fire flow than necessary.
- Zone 4 was assumed to be served by a booster pump and separated from Zone 3 with an
 additional PRV, after initial model results showed lower pressure than required in Zone 4.
- Pipe diameter was initially assumed to be 12-inch but was upsized to 16-inch after undesirable fire flow and pipe velocity resulted.

Results from modeling the City Heights development according to the above assumptions indicate 16-inch diameter pipe will be necessary to adequately serve the development at full buildout, and services in Zone 4 will not have sufficient pressure to be served by Zone 3 water main. The solution to serve Zone 4 represented in the model is not recommended for implementing because it satisfies the model's instantaneous demand but would not support real-life fluctuating demands over time.

Depending on the method used for serving Zone 4, water main diameter in Zone 4 and to the east may potentially be reduced to 12-inch. Services at the low end of the pressure zone they are

Blueline June 17, 2020 Page 2

served from may use individual PRVs where it is more practical than extending water mains from the lower zone or installing a larger PRV station in the City's water main. If the H Pods isolated from the rest of the system are served by one or more wells, the City will regard that location either as a neighboring water system or rural residential area. The City will not operate or be responsible for the well(s) serving that area. If in the future the City extends water amins to this area, the lots may connect to City water, but must be disconnected from their previous source for potable use.

Please feel free to contact me for clarification or for further questions.

Very truly yours,

Ryan M. Young, PE

RMY/sms

Copy: City of Cle Elum





^{*} א [©] ii **© 2020 BLUELINE**



WATER PI	RESSURE ZONES	APPROX. WS EL
ZONE 1	(1,865' – 1,965')	2,065
ZONE 2	(1,965' – 2,080')	2,176
ZONE 3	(2,080' – 2,200')	2,302
ZONE 4	(> 2,200')	TBD



WATER P	RESSURE ZONES	APPROX. WS EL IN RESEVOIR
ZONE 1	(1,865' — 1,965')	2,065
ZONE 2	(1,965' — 2,080')	2,176
ZONE 3	(2,080' – 2,200')	2,302
ZONE 4	(> 2,200')	TBD

INFORMATION FROM FIGURE 3.3 OF THE CITY OF CLE ELUM/TOWN OF SOUTH CLE ELUM WATER SYSTEM UPDATE PREPARED BY HLA.

APPDROXIMATE ELEVATION RANGE IS A GENERAL ESTIMATE FOR PLANNING PURPOSES INTENDED TO SHOW ELEVATION RANGES THAT PROVIDE BETWEEN 40 AND 100 PSI. ACTUAL PRESSURES AND ELEVATION RANGES MAY VARY BASED ON SITE SPECIFIC REVIEW.



N

WATER NOTES

PHASE 1A SERVED OFF ZONE 2 WATER SYSTEM. • PROVIDE FIRE HYDRANTS AT 600' MAX SPACING.